

MRO 2023 REGIONAL SUMMER ASSESSMENT

MRO Reliability Analysis Department
June 29, 2023
10:00 a.m. – 11:00 a.m. Central

Cris Zimmerman, MRO
Salva Andiappan, MRO
Max Desruisseaux, MRO
David Kuyper, MRO
John Grimm, MRO

CLARITY

ASSURANCE

RESULTS



Cris Zimmerman

Manager of Outreach and Stakeholder Engagement

CLARITY

ASSURANCE

RESULTS

MRO Upcoming Events

Conferences

- July 25th CMEP Networking Reception, St. Paul
- July 26th CMEP Hybrid Conference, St. Paul
- Sept 26th 28th Hybrid Security Conference in OKC



WebEx Chat Feature

Open the Chat Feature:




The chat feature will appear to the right of the WebEx window.

Attendees should chat their questions to: "All Panelists".

Select All Panelists by using the drop-down arrow in the "To" field.





The ERO Enterprise and MRO

MRO's Mission Supports the Vision

To identify, prioritize and assure effective and efficient mitigation of risks to the reliability and security of the North American bulk power system by promoting Highly Effective Reliability OrganizationsTM (HEROs).





FIVE BASIC PRINCIPLES:

1. Preoccupation with failure

Attention on close calls and near misses ("being lucky vs. being good"); focus more on failures rather than successes.

2. Reluctance to simplify interpretations
Solid "root cause" analysis practices.

3. Sensitivity to operations

Situational awareness and carefully designed change management processes.

4. Commitment to Resilience

Resources are continually devoted to corrective action plans and training.

5. Deference to Expertise

Listen to your experts on the front lines (ex. authority follows expertise).

Classification: Public

Annual HERO Award

Nominate Someone Today!







www.mro.net/about/hero/





Salva Andiappan

Principal Reliability Assessment Engineer

CLARITY

ASSURANCE

RESULTS

MRO 2023 Regional Summer Assessment

- Summer Seasonal Forecast and Recommendations
- BES Event Analysis (EA) and Energy Emergency Alerts (EEA)
- Generator Availability Data System (GADS)
- Transmission Availability Data System (TADS)
- Misoperations Information Data Analysis System (MIDAS)



2023 Summer Seasonal Forecast

- Data is collected and analyzed based on each PCs footprint.
- Assessment period from June 2023 through Sept. 2023.
- Reserve Margin % used as an indication of adequacy.
- Analysis looks at two different load and outage conditions:
 - Normal peak load forecast with typical outages
 - Extreme peak load forecast with extreme derates



Normal Peak Demand with Typical Outages

Assessment Area	Anticipated Resources	Typical Maintenance and Forced Outages	Anticipated Resources with Typical Outages	Normal Peak Load	Anticipated Reserve Margin with Typical Outages	Planning Reserve Margin
МН	3,950	106	3,844	3,060	25.6%	12.0%
MISO	143,668	21,853	121,815	116,825	4.3%	15.9%
SPC	4,503	568	3,935	3,489	12.8%	15.0%
SPP	65,583	5,450	60,133	52,626	14.3%	19.0%

Anticipated Reserve Margin for Normal Load Forecast with Typical Outages (in MWs)

• MH, MISO, SPC and SPP have sufficient operating reserve to meet normal forecasted peak load with typical outages.



Extreme Peak Demand and Derates

Assessment Area	Anticipated Resources with Typical Outages	Extreme Derates	Extreme Low Generation	Operational Mitigations	Extreme Low Generation + Operational Mitigations	Extreme Peak Load
МН	3,844	10	3,834	0	3,834	3,390
MISO	121,815	8,950	112,865	2,400	115,265	123,871
SPC	3,935	372	3,563	347	3,910	3,633
SPP	60,133	7,196	52,937	0	52,937	55,126

Extreme Peak Demand and Derates (in MWs)

 MISO and SPP has insufficient resources to cover extreme condition and could result in operating mitigations and/or Energy Emergency Alerts



Normal vs. Typical Outages vs. Extreme Derates

Assessment	PRM	With No	With Typical	With Extreme
Area	Requirement	Outages	Outages	Outages
МН	12.0%	29.1%	25.6%	+13.1%
MISO	15.9%	23.0%	4.3%	-6.9%
SPC	15.0%	29.1%	12.8%	+7.6%
SPP	19.0%	24.6%	14.3%	-4.0%



Recommendations

- Maintain situational awareness of unplanned generation and transmission outages, abnormal and extreme weather conditions, and low wind forecast period.
- Have safeguard protocols in place to ensure adequate generation resources are available prior to the summer season high demand period and plans for managing emergency requests from grid operators.
- Develop new and improved methods to assess and evaluate supply adequacy.





For more information, please contact:

Salva Andiappan
Principal Reliability Assessment Engineer
Salva.Andiappan@mro.net

Questions



Max Desruisseaux

Senior Power Systems Engineer


CLARITY

ASSURANCE

RESULTS

- Data is collected and analyzed based on MRO regional footprint.
- Review historical performance of bulk power system events.
- Follows the <u>ERO Event Analysis Process</u>.
- Registered Entity develops a brief report.
- Perform root cause analysis.
- Provide recommendations and lessons learned.






MRO Event Severity Index



- Total of 17 transmission events from Jan. 2022 thru Dec. 2022.
- 2 of 17 events occurred in summer 2022.
- All of the summer events related to unintended operation of protection systems.
- 3 EMS event occurred in summer 2022.





Loss of EMS Event Time Duration



Energy Emergency Alerts (EEA)

- Energy Emergency Alerts (EEAs) are issued by RCs per <u>EOP-011-2.</u>
- 2 EEA Level 2 alert issued during June 2022
- 2 EEA Level 2 alert issued during July 2022
- 1 EEA Level 1 alert issued during August 2022
- All events had no firm load shed





For more information, please contact:

Max Desruisseaux
Senior Power Systems Engineer

Max.Desruisseaux@mro.net

Questions



David Kuyper

Power Systems Engineer II

CLARITY


ASSURANCE

RESULTS

- Data is collected and analyzed based on MRO regional footprint.
- Review historical performance on conventional generators 20 MW and larger, and wind turbine 75 MW or greater.
- Collected per <u>Section 1600</u> data request.
- Wind turbine component outage information not included in this assessment until mandatory and representative data sets are available.



Resource Mix




Petroleum, _ Solar, _Other, 1680 3011 1805 Nuclear, 3763 Conventional. Hydro, 11931 Natural Gas, 45937 Wind, 13680 Coal, 37648

MRO 2023 Summer Nameplate

MRO 2023 Summer Peak Capacity






MRO Annual Generator MW-Weighted EFOR

Long term trends continue to indicate increasing EFOR rates.






MW-Weighted EFOR By Month



- 2022 summer saw higher generator event impact than last summer
- Fossil steam had higher event impacts and increased WEFOR percentages in August and September
- Fossil-steam generation showed high event impact but overall have lower impact to the BES
- Top 5 2022 Summer Cause Types: Waterwall, Unit Auxiliaries Transformer, First Reheater, Buckets or Blades C and Circulating Water Pumps





Total Event Impact and Number of Event Impact for Summer 2022





For more information, please contact:

David Kuyper
Power System Engineer II

David.Kuyper@mro.net

Questions



John Grimm

Principal Systems Protection Engineer

CLARITY

ASSURANCE

RESULTS


Transmission Availability Data System (TADS)

- Data is collected and analyzed based on MRO regional footprint.
- Review historical performance on transmission lines and transformers 100-kV and above.
- Collected per Section 1600 data request.



RESULTS


Transmission Availability Data System (TADS)



Summer 2018-2022 Automatic Outages by Month




Transmission Availability Data System (TADS)



Summer 2022 Momentary Outages by Cause




Transmission Availability Data System (TADS)



Summer 2022 Sustained Outages by Cause



Transmission Availability Data System (TADS)




Summer Total Transmission Outages per 100 Circuit Miles

- Decreasing outages for 2020-2021 summer and levelling off in 2022
- High momentary outages for 300-399kV circuits in 2019



- Data is collected and analyzed based on MRO regional footprint.
- Review historical performance on protection system operations and misoperations.
- Collected per Section 1600 data request.







- Upward trend seen in 2020 and 2021 did not continue in 2022
- Total protection system operations increased about 25 percent and total misoperations increased approximately 22 percent.

Misoperation Rate = (No. of Misoperations / No. of Total Operations) X 100%








Protection System Operations by Year


Misoperations by Year






Total Operations (Spring/Summer vs. Autumn/Winter)





Fault Associated and Non-Fault Associated Misoperations





Summer 2022 Misoperations by Cause

- Total 93 misoperations between June 1, 2022 and September 30, 2022
- 28% were attributable to Human Errors





For more information, please contact:

John Grimm
Principal Systems Protection Engineer
John.Grimm@mro.net

Questions

Thank you for attending this event!



https://www.surveymonkey.com/r/6WXSCSV

