



Load Forecast Uncertainty: Dynamic Reserves at MISO

2026 MRO Reliability, Security and CMEP Summit

May 13, 2026


Purpose

Share recent and ongoing work at MISO to enhance operating reserve products with dynamic reserves to prepare for increased uncertainty and variability with more weather-dependent generation

Key Takeaways

- Operational challenges are magnifying as the resource mix evolves and has materialized on discrete days
- In response, reserves for each operating day will no longer be static quantities and, instead, will change daily
- AI/ML will be used to calculate reserves based upon forecasted uncertainty and variability for each operating day

Meet MISO



MISO's reliability footprint and regional offices



KEY FACTS

Area Served	15 U.S. States and Manitoba, Canada
Population Served	45 Million
Transmission Line	79,000 Miles
Generating Units	Approximately 2,000
Record Demand	127.1 GW 7/20/2011
Wind Peak	26.6 GW 1/3/2026
Solar Peak	18.6 GW on 4/20/2025
Total MISO Members	230+
Market Participants	550+
Market Transactions	Over \$53 billion in 2025
Carbon Reduction	Approximately 32% since 2014

The solar growth trend will result in increasing net load ramps, potentially exceeding 100 GW by 2043

Installed Solar Capacity (GW)


System Net Load (GW)



MISO IS MEETING THIS EVOLVING NEED BY

- Dynamically determining ramp capability reserve needs
- Enhancing how we commit and dispatch generation
- Evaluating need for market products to manage longer-term ramp

Coordinating and executing on the priorities within the Reliability Imperative is required to address challenges to reliability




MISO operates Day-Ahead and Real-Time Energy and Ancillary Service markets with reliability commitments in-between



- In addition to the operating horizon, MISO also administers markets in the planning horizon
 - Planning Resource Auction (PRA)
 - Auction Revenue Rights (ARR) and Financial Transmission Rights (FTR)
- After Real-Time market, Automated Generation Control (AGC) ensures generation is balanced with actual load every four seconds

The Energy and Ancillary Service markets co-optimize Energy and reserve products that cover uncertainties across different timeframes



MISO is making Next Day reserve margin, Short-Term Reserve, Ramp Capability Product and Regulation Reserve “dynamic”

Net Uncertainty Forecast and Dynamic Reserve process includes two key design features

1. Set different levels of Reserve Requirements (Normal /High)

- This is similar to having different insurance coverage
- Normal/High requirements are derived from quantified net uncertainty from historical market days
- Reserve Requirements are updated every season

2. Mechanism to *forecast* uncertainty and *dynamically change* Reserve Requirements in advance

- Different reserve products require separate forecast mechanisms/models
- When forecast models predict HIGH uncertainty for any of the reserve products, reserve requirements are overwritten to High level*

* before Day-Ahead market closes at 10:30 EPT

Net Uncertainty Quantification and Seasonal Reserve Requirements

Product	ND FRAC Commitment Threshold*	Short-Term Reserve	Ramp Capability (Uncertainty Component)	Regulation Reserve
Quantified Uncertainty Component	Timeframe: Next-Day <ul style="list-style-type: none"> • Gen Availability • Load • Renewable • NSI • Stranded MW 	Timeframe: 30min to 3hour <ul style="list-style-type: none"> • Netload error • Generation outage/derate • Commitment 	Timeframe: 10min <ul style="list-style-type: none"> • Netload error • Thermal generation not following dispatch 	Timeframe: 4sec to 5min <ul style="list-style-type: none"> • Tie Error • Regulation MW not available due to ramp sharing
Requirements	Normal / Medium / High <ul style="list-style-type: none"> • Four seasons • Systemwide / NorthCentral / South 	Normal / High <ul style="list-style-type: none"> • 24 hours × four seasons • Systemwide / NorthCentral / South 	Normal / High <ul style="list-style-type: none"> • 24 hours × four seasons • Systemwide 	Normal / High <ul style="list-style-type: none"> • 24 hours × monthly × weekday/weekend • Systemwide
Reference		doi: 10.1109/TPWRS.2022.3200697** 20260414 RSC Item 07	20250828 RSC Item 09 20260414 RSC Item 07	20250417 RSC Item 05 20260414 RSC Item 07

* Currently managed by Next-Day (ND) Forward Reliability Assessment and Commitment (FRAC) Operating process. **Not a market product.**

** Y. Chen, "Addressing Uncertainties Through Improved Reserve Product Design," in IEEE Transactions on Power Systems, vol. 38, no. 4, pp. 3911-3923, July 2023


Net Uncertainty Forecast Models for each reserve product

Product	ND FRAC Commitment Threshold* & Short-Term Reserve	Ramp Capability (Uncertainty Component)	Regulation Reserve
Net Uncertainty Forecast Model	ND FRAC Net Uncertainty Forecast Model	Up Ramp Uncertainty Forecast/Classifier Model	Regulation Uncertainty Forecast/Classifier Model
Forecast Output	Hourly uncertainty MW (then converted to Low/Medium/High labels)	Hourly uncertainty labels (Normal / High)	Hourly uncertainty labels (Normal / High)
Implication	<ul style="list-style-type: none"> Set Commitment Threshold recommendation according to L/M/H labels Set Short-Term Reserve to High requirement for hours with High uncertainty label in next operating day 	Set Ramp Capability (Uncertainty Component) to High requirement for hours with High uncertainty label in next operating day	Set Regulation Reserve to High requirement for hours with High uncertainty label in next operating day
State	<ul style="list-style-type: none"> January 2024 (peak load hour full implementation) March 2026 (all-hour uncertainty full implementation) 	<ul style="list-style-type: none"> June 2025 (Requirement) Estimate June 2026 (full implementation) 	<ul style="list-style-type: none"> March 2026 (Requirement) Estimate Sept 2026 (full implementation)

* Currently managed by Next-Day (ND) Forward Reliability Assessment and Commitment (FRAC) Operating process. **Not a market product.**

Short-Term Reserves


Operations of the Future work and dynamic STR have positioned MISO well for efficient reliability through the fleet transition, as evidenced by our performance across major storms.



Source: MISO Operations Report, Markets Committee of the Board of Directors, March 11, 2025

Day Ahead Net Load Uncertainty Prediction Machine Learning model is used to Dynamically Set Short-Term Reserve Requirement and Next-Day Reserve Margin Threshold

Example day assessing multiple ML models in development



ML model predicts high uncertainty and risk that materialized at actual and forecasted peak load hour

- MISO uses deterministic day ahead net load uncertainty prediction ML model to dynamically set Short-Term Reserve requirement and Next-Day reserve margin threshold.
- Markets R&D is exploring probabilistic day ahead net uncertainty prediction models


MISO begins transition to all-hour uncertainty, moving away from traditional peak-hour.

Unprecedented load growth, significant increases in renewable generation, non-conforming loads, and complex load pockets continue to challenge the complexities of load forecasting and managing uncertainty.

MISO is moving away from traditional peak-hour forecasting.

All-hours are important and it has become critical to understand the risk and uncertainty for each hour.

All-Hour Uncertainty




ML model predicts high, medium, or low uncertainty for each hour

Ramp Capability Product

Ramp Capability Product Requirement

- Ramp Capability Product is designed to manage both expected (variations) and unexpected (uncertainties) in the “net load”



Dynamic Ramp Capability Product Requirement (Uncertainty Component)

- 10min Ramp Net Uncertainty Quantification and Requirement for Ramp Capability Product (RCP) Uncertainty Component


Component 1: Net Load Uncertainty	Component 2: Gen Error (Thermal units not following dispatch)
<p>For each UDS interval:</p> <p>10min Net Load Uncertainty = Load Uncertainty 10min - (Wind Uncertainty 10min + Solar Uncertainty 10min),</p> <p>where</p> <p>Load Uncertainty 10min = Load Actual - Short-Term Load Forecast</p> <p>Wind/Solar Uncertainty 10min = (Wind/Solar Actual + Curtailment) - wind/solar short-term forecast</p>	<p>For each UDS interval:</p> <p>Track each thermal unit's dispatch MW and energy MW and calculate the difference</p>
Hourly values are determined by 95 th (Normal) and 97 th (High) percentiles of Up Uncertainty	Hourly values are determined by 95 th (Normal) and 97 th (High) percentiles of Abs (Negative Gen Uncertainty)

For deriving RCP Uncertainty Component:

Component 1 [(95 / 97 percentile)] +
Component 2 [(95 / 97 percentile)]

Seasonally-updated Ramp Capability Product up uncertainty component requirement varies each hour, better reflecting the anticipated uncertainty hourly variation

- Normal uncertainty Ramp Capability Product Up requirements are calculated and published seasonally
- High uncertainty Ramp Capability Product Up requirements will be published later in 2026 when operationalized



Regulation

Dynamic Regulation Reserve Requirement

- Methodology Improvement for derive Regulation Requirement


Component 1: Tie Error	Component 2: Regulation Capacity not available for deployment because of ramp sharing
Historical data: Same season over the last two years with 70% weight on last year	
Hourly values are determined by 95 th (Normal) and 97 th (High) percentiles plus a scaling factor to account for growth of renewable capacity	Mean of Component 2

For deriving Regulation Requirement:


$$\begin{aligned} & \text{Component 1 [95 / 97 percentile]} * \text{scaling factor} \\ & + \\ & \text{Component 2 [Mean]} \end{aligned}$$

Seasonally-updated monthly Regulation reserve requirement varies each month and hour, better reflecting the anticipated monthly and hourly uncertainty variation

Comparison of Spring 2026 Monthly Weekday Regulation Reserve Requirement to Previously Used Static Requirement



Comparison of Spring 2026 Monthly Weekend Regulation Reserve Requirement to Previously Used Static Requirement



Next Steps

- Apply the next-day process to change the Regulation and Ramp requirements dynamically based on high or normal uncertainty
 - Test Regulation and Ramp forecast uncertainty Machine Learning models
 - Apply the process
- Improve Short-Term Reserve all hours uncertainty process
 - Test all hours Short-Term Reserve uncertainty forecast classification model
 - Apply process improvements

Contact

Christine Ross

cross@misoenergy.org

Appendix

Resources

- Short-Term Reserve Uncertainty design described in paper: Y. Chen, "Addressing Uncertainties Through Improved Reserve Product Design," in *IEEE Transactions on Power Systems*, vol. 38, no. 4, pp. 3911-3923, July 2023, doi: 10.1109/TPWRS.2022.3200697.
- STR, Ramp Capability, and Regulation Requirements are posted under Related Documents on the Market Subcommittee (MSC) page on the MISO website at via the URL below:

Engage > Stakeholder Entities and Workshop > Market Subcommittee > Related Documents
<https://www.misoenergy.org/engage/committees/market-subcommittee/>

- Stakeholder materials posted for MISO Dashboard items:
 - [RSC-2024-1: Dynamic Regulation Reserve Requirement](#)
 - [RSC-2024-2: Dynamic Ramp Capability Product Requirement \(Uncertainty Component\)](#)

OUR FUTURE, OUR PLAN FOR NUCLEAR POWER

MRO Reliability, Security and CMEP Summit

May 13, 2026

David M. Brock



About Saskatchewan

We have the **food, fuel, fertilizer and the critical minerals** the world needs.



About Saskatchewan



Area: 651,036 km² (251,366 mi²)

Almost the size of Texas

Home to 1.27 million people

Centre of the North American power grid



About SaskPower

**STATE-OWNED
ENTERPRISE**


**VERTICALLY
INTEGRATED
UTILITY**

**560,000
CUSTOMERS**


**6,000 MW
CAPACITY**

**159,000 KM OF
POWER LINES**

**3,910MW
RECORD PEAK
LOAD**




Ownership and Oversight



SaskPower's Sources of Financing

\$3 billion annual operating budget
\$1.5 billion annual capital spend



Saskatchewan's Nuclear Future Builds on a Strong Legacy



Strong Uranium Supply; High Fuel-Switching Costs

Home to the world's highest grade uranium deposits

2nd largest uranium producer globally (2024)

24% global production (2024)

\$3.2 billion in uranium sales(2025)

#1 uranium supplier to the U.S. and Canada's only producer

36% of U.S. uranium deliveries were from Saskatchewan (2024)



World Class Research and Expertise

Sylvia Fedoruk Centre for Nuclear Innovation


Advances nuclear science by funding research, building expertise and operating Saskatchewan's state-of-the-art 24 MeV cyclotron to support medical isotopes, nuclear medicine and energy innovation.

Canadian Light Source Synchrotron

Canada's only synchrotron. Supports nuclear power through research across the full lifecycle: from fuel source (uranium mining), to reactor materials and safety (advanced material analysis), to novel fuel forms (chemistry), and nuclear waste containment.

Radiation Safety Institute of Canada

Canada's only independent, national organization focussed exclusively on promoting and advancing radiation safety in the workplace, the environment and in the community.



Research and Training

- Western Canada's first SMR Safety, Licensing, and Testing Centre will advance nuclear research and support nuclear workforce and supply chain development.
- Nuclear research chairs being established by the Sylvia Fedoruk Centre for Nuclear Innovation and the University Network for Excellence in Nuclear Engineering






NUCLEAR POWER AS THE FUTURE

Energy Security Strategy and Supply Plan

Strong policy support; but building a nuclear facility takes many years.

An all-of-the-
above approach



Coal as a
bridge to
nuclear

Nuclear
power as the
future



Transmission
infrastructure

Saskatchewan First
Energy Security Strategy and Supply Plan

saskatchewan.ca

Saskatchewan
Canada



Energy Security Strategy and Supply Plan

An all-of-the-above approach

- Coal & Natural Gas
- Hydro (in-province and imports)
- Wind & Solar
- SMR
- Other (biomass, flare gas, landfill gas, waste heat)
- Planning for a net-zero electricity system by 2050

Coal as a bridge to nuclear

- Established Coal Life Extension team
- Planning for 25-year life extensions of all seven coal units
- Planning for coal mine relocations for supply beyond 2029
- Negotiating coal supply contracts beyond 2029
- Potential for future CCS on coal units

Nuclear power as the future



- Established SaskNuclear
- Advancing planning and licensing work for SMRs
- Final SMR site selection decision in 2026
- Supply chain development and partner selection
- Beginning evaluation of large reactor technologies

Transmission infrastructure

- SPP interconnection
- Transmission reinforcement throughout province
- North-South Systems Interconnection
- Northwest System Expansion




Modest Provincial Demand; Growing Regional Demand For Energy Security




SaskNuclear

- Wholly-owned nuclear subsidiary to license and construct nuclear power plants in Saskatchewan.
- Will have autonomy in decisions and actions to build nuclear, while maintaining guidance and support from SaskPower's leadership and board.



SaskNuclear Organizational Structure




Small Modular Reactor Project

Small Modular Reactors (SMRs) are to bridge from coal-to-nuclear, adding more reliable baseload power to our grid.

We've selected the GE Vernova Hitachi BWRX-300 SMR for potential deployment in Saskatchewan.




Building a SMR Facility



Ongoing Indigenous, Stakeholder and Public Engagement



SMR Project Timeline








Selecting a Site for Further Evaluation

Determining the site for Saskatchewan's first nuclear power plant with capacity to host up to two SMRs.




Two Candidate Sites in Southeast Saskatchewan

(Boundaries are approximate)

-  Candidate Site
-  Potential siting area
-  Proposed study area
-  First Nation Reserves
-  Protected Lands

This map encompasses the traditional territories of the First Nations and Métis peoples.



Engagement and Consultation

- Consulted with Rightsholders
- Continue engagement with Indigenous peoples, municipal leaders and communities in the Estevan Region.
- Since 2022, we've exceeded 9,500 interactions through 200 in-person and online opportunities to share information and collect input to inform the site selection.



Site Evaluation and Characterization Planning


We're developing a comprehensive plan to begin site evaluation and characterization following site selection.

This work will support the License to Prepare Site application and will include:

- Geotechnical, hydrological and external hazard studies
- Determine environmental and socio-economic baselines
- Effects and impact assessments are required under the *Impact Assessment Act*



Federal and Provincial Regulators



  **Decide whether project progresses.**



Supply Chain

- Advancing our planning to select a nuclear-experienced construction and engineering partner to design, buy equipment and build the SMR facility
- Engaging early with our primary construction and engineering partners helps us qualify and build nuclear expertise in Saskatchewan
- Indigenous and local participation plans are an important part of the project



Workforce

- 89,000 jobs in Canada's nuclear industry
- Saskatchewan will need 2,500 to 3,500 skilled workers, largely in the trades to build and operate the SMR facility.
- Working with Indigenous partners to determine pathways for Indigenous peoples to develop the skills needed to participate in upcoming workforce needs.



Economic Growth

SMRs are a part of a wider energy transition in Saskatchewan that can provide communities and industries with reliable heat and power while creating high-quality jobs, and local economic development.



Large Nuclear Technology Evaluation

Evaluating large reactor technologies.

Commissioning a large reactor can take 15 to 20 years.



A Trusted Global Fuel Partner with Strong Nuclear Supply Chain Potential

Canada:

2nd largest global uranium producer (SK), nuclear fuel services (ON), nuclear power plants (ON & NB)

United Kingdom:

Approx. 15% of electricity from nuclear; conversion, enrichment, reprocessing, and waste capacity

France:

About 70% of electricity from nuclear, 56 operable reactors, conversion, enrichment, and fuel fabrication capacity

Japan:

Hosts a full fuel cycle, including enrichment, 33 operable reactors

Poland:

Pursuing nuclear power deployment and supply diversification through international partnerships.

China:

Self-sufficient in most aspects of the fuel cycle, 56 operable reactors



United States:

World's largest producer of nuclear power, 94 operable reactors, conversion, enrichment, and fuel fabrication capacity



A Reliable Partner at the Centre of Power in North America

Transmission: intra-provincial, inter-provincial, and international dispatch mix of reliable baseload power.

Southwest Power Pool (SPP) interties will expand export capacity to 650 MW, positioning Saskatchewan as a reliable power partner.





THANK YOU

